

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

		1. CONTRACT ID CODE		PAGE OF PAGES 1 5	
2. AMENDMENT/MODIFICATION NO. 001		3. EFFECTIVE DATE May 22, 2006		4. REQUISITION/PURCHASE REQ. NO.	
				5. PROJECT NO. (If applicable)	
6. ISSUED BY ARCHITECT OF THE CAPITOL United States Capitol Washington, D.C. 20515			7. ADDRESS AMENDMENT/MODIFICATION TO Architect of the Capitol Procurement Division Ford House Office Building Attn: Chris Lindsay Room H2-263 Second and "D" Streets, S.W. Washington, DC 20515		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. RFP No. 060104
					9B. DATED (See Item 11) April 20, 2006
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (See Item 13)
CODE		FACILITY CODE			
SUBJECT: ADDITIONAL ROOF FALL PROTECTION AT THE U.S. SUPREME COURT, WASHINGTON, DC					

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of offers **XXX** is extended, **_** is not extended. **THE DUE DATE FOR PROPOSALS IN JUNE 1, 2006 AT 1PM EST.**

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and return ___ copies of the amendment; (b) By acknowledging receipt of this amendment in Block 12 of Page 1 of the solicitation package, giving amendment number and its date; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. **FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.** If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter make reference to the solicitation and this amendment, and is received prior to the opening/receipt hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.			
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).			
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:			
D. OTHER (Specify type of modification and authority)			
E. IMPORTANT: Contractor _____ is not, _____ is required to sign this document and return it to the issuing office.			
14. DESCRIPTION OF AMENDMENT/MODIFICATION 1. SEE CONTINUATION PAGES. Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.			
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA By _____ (Signature of Contracting Officer)	16C. DATE SIGNED

A. This Amendment No. 001 is issued to provide the list of attendees at the site visit held on May 3, 2006, provide answers to questions submitted as of May 12, 2006, and to include a SF 1442 - "Solicitation, Offer, and Award (Construction, Alteration, and Repair)" form that was omitted from the solicitation. **Also the due date for proposal has been extended to JUNE 1, 2006 at 1PM EST.** All other terms and conditions remain the same.

Attachments:

List of Attendees (1 page)
Question and Answers (2 pages)
SF 1442 (2 pages)

Distribution:

Contract File
COTR -

Additional Roof Fall Protection at the U.S. Supreme Court, Washington, D.C.

RFP No. 060104

Site Visit Attendees

PRE-PROPOSAL MEETING & SITE VISIT

LIST OF ATTENDEES

May 3, 2006- 10:00 a.m.

LIST OF ATTENDEES

<u>Names</u>	<u>Representing</u>	<u>Telephone & FAX Numbers</u>
James Wholey	Acrotech Rigging & Access Services	240-832-0545 301-854-2882
Hans Zander	Winsafe Corp.	905-474-9340 905-474-9341
Paul Chase	Safety Systems, Inc.	734-414-7680 734-414-7706
Doug Fear	Hysafe Technology	708-417-8453 262-752-2410
John Whitty	ITAC Fall Protection Services	804-414-1132 804-414-1195
Darren Borman	Simpson Unlimited, Inc.	703-361-0841 703-361-1341

Representing the Architect of the Capitol

Chris Lindsay	AOC-Contract Specialist/Procurement Division	202-479-5976 866-221-4147
Don Stambaugh	AOC-Facilities Operations Specialist/USSC	202-479-3366 202-479-3045
Marc Frampton	AOC-Facilities Manager/USSC	202-479-3219
Howard Wagner	AOC-Project Management Division	202-226-4712

Additional Roof Fall Protection at the U.S. Supreme Court, Washington, D.C.
RFP No. 060104
Questions and Answers

1. Question: What is the procedure for the men to get to the roof and how long of a process is it?

Answer: Security clearances will be required for all contract personnel who will be working in the building. Contractor to provide the following employee information to the COTR:

- Full name plus any aliases or other surnames used
- SS#
- Race
- DOB
- Current address (no PO Box)

- Contractor names who have passed security will receive a "Contractor" badge when they report for the first time to the job.
- Contractor employees must enter and leave the building through the Maryland Ave entrance.

Once cleared, employees will need to arrange in advance for an escort through the COTR and will need to be escorted to the work areas on a daily basis. Arrangements for an escort will need to be made the day prior.

2. Question: Is there going to be a certified testing requirement for the Davits?

Answer: Yes. see section 14430 1.2.D and 1.3.A

3. Question: Could you supply the Manufacturer, color and type of tile?

Answer: The original tile manufacturer is no longer in business . The AOC is in the process of planning additional Supreme Court Roof Restoration. Part of that work will be replacement of broken roof glazed terra cotta tile. As in this project, glazed terra cotta tile will be required to match existing in all respects. Two US companies being considered for this work are :

Boston Valley Terra Cotta
Gretchen Krouse, Vice President
716-649-7490

and
Gladding McBean
916-645-3341
1-800-776-1133
Contact - Pete Pederson

4. **Question:** Any Lightning protection required for the davits?

Answer: No. This will be incorporated in the roof repair project scheduled for a later date.

5. **Question:** Details 2, 4 and 5 on Dwg. A501 indicate adhesive fasteners to attach the roof anchors to the concrete slab. The anchor depth is indicated as 2" and 2 ½", neither of which would provide adequate strength to meet design code compliancy. Could you please advise us on how we can deal with this matter in our bid.

Answer: Based on calculations performed by this office, there are epoxy adhesive anchors that will provide the required pullout resistance for the specified embedment depths and design loads.

Specification Section 05500, Paragraph 2.3.F.1. references an ultimate pullout resistance of 8520 pounds. This is correct for the high roof anchors. The ultimate pullout resistance for the low roof anchors should be 6960 pounds. These resistances are based on manufacturer's published data for the anchor size and concrete strength.

Based on our structural loading calculations, the required ultimate pull out resistance to meet the load criteria for both locations is 6500 pounds.

6. **Note:** DRAWING No. E101, Note No. 1 reads "MANLIFT (460V, 3PH, 10 HP)". It should read "MANLIFT (**240V**, 3PH, 10 HP)"

SOLICITATION, OFFER, AND AWARD <i>(Construction, Alteration, or Repair)</i> January 2004	1. SOLICITATION NO.	2. TYPE OF SOLICITATION	3. DATE ISSUED	PAGE OF PAGES	
	RFP NO. 060104	____ SEALED BID (<i>IFB</i>) <u>XX</u> NEGOTIATED (<i>RFP</i>)	APRIL 20, 2006	1	2

IMPORTANT - The "offer" section on page 2 of 2 must be fully completed by offeror.

4. CONTRACT NO.	5. REQUISITION NO. SC 060139	6. PROJECT NO. 990114A
7. ISSUED BY ARCHITECT OF THE CAPITOL United States Capitol Washington, D.C. 20515		8. ADDRESS OFFER TO (Note - All handcarried offers/bids will be rejected) Architect of the Capitol Procurement Division Ford House Office Building Attn: Chris Lindsay Room H2-263 Bid Room Second and "D" Streets, S.W. Washington, DC 20515
9. FOR INFORMATION CALL: A. NAME CHRIS LINDSAY		B. TELEPHONE NO. (<i>Include area code</i>) (<i>NO COLLECT CALLS</i>) (202) 479-5976

SOLICITATION

NOTE: In sealed bid solicitations "offer" and "offeror" mean "bid" and "bidder".

SUBJECT: **ADDITIONAL ROOF FALL PROTECTION, U.S. SUPREME COURT**

10. THE GOVERNMENT REQUIRES PERFORMANCE OF THE WORK DESCRIBED IN THESE DOCUMENTS (*Title, identifying no., date*):

- A SITE VISIT AND PRE-BID CONFERENCE WILL BE CONDUCTED ON MAY 3, 2006 AT 10:00 AM EST. ADDITIONAL INFORMATION is located in the article entitled "VISIT TO THE SITE OF THE WORK " IN THE SOLICITATION CONDITIONS.**
- The Offeror's attention is directed to the "SUPPLEMENTARY CONDITIONS", 2. SUBMITTALS, which will be strictly enforced.**

11. The CONTRACTOR shall complete performance by **September 13, 2007 or September 13, 2008**. See Supplemental Conditions, article entitled "CONTRACT TIME".

12. The CONTRACTOR must furnish any required performance, payment bonds and insurance: x YES ___NO. If YES, within 20 calendar days after award.

13. ADDITIONAL SOLICITATION REQUIREMENTS:

A. Sealed offers in original and 2 copies to perform the work required are due at the place specified in Item 8 by 1:00 p.m. (*hour*) local time June 1, 2006 (*date*). If this is a sealed bid solicitation, offers must be publicly opened at that time. Sealed envelopes containing offers shall be marked to show the offeror's name and address, the solicitation number, and the date and time offers are due.

B. An offer guarantee X is, ___ is not required.

C. All offers are subject to the (1) work requirements, and (2) other provisions and clauses incorporated in the solicitation in full text or by reference.

D. Offers providing less than 60 Calendar days for Government acceptance after the date offers are due will not be considered and will be rejected.

OFFER (Must be fully completed by offeror)

14. NAME AND ADDRESS OF OFFEROR (Include ZIP Code)

DUNS NO. _____ TIN _____

15. TELEPHONE & FACSIMILE NOS. (Include area codes)

16. REMITTANCE ADDRESS (Include only if different than Item 14)

17. The offeror agrees to perform the work required at the prices specified in the Schedule in strict accordance with the terms of this solicitation, if this offer is accepted by the Government in writing within 60 calendar days after the date offers are due.

18. The Offeror agrees to furnish any required performance, payment bonds and insurance.

19. ACKNOWLEDGMENT OF AMENDMENTS

(The offeror acknowledges receipt of amendments to the solicitation - give number and date of each)

AMENDMENT NO.										
DATE										
20A. NAME AND TITLE OF PERSON AUTHORIZED TO SIGN OFFER (Type or print)				20B. SIGNATURE					20C. OFFER DATE	

AWARD (To be completed by Government)

21. ITEMS ACCEPTED:

22. AMOUNT

23. ACCOUNTING AND APPROPRIATION

2006 X0103 990114A P3210 3220 LA02110003 0000; 2006 X0103 990114A P3400 3220 LA02110003 0000; 2006 X0103 990114A P3220 3220 LA02110003 0000

24. SUBMIT INVOICES TO ADDRESS SHOWN IN ITEM _____ 27 _____

(In Triplicate)

25. AUTHORITY FOR NEGOTIATION, IF APPLICABLE

26. ADMINISTERED BY:

CODE _____

See Block 8

27. PAYMENT WILL BE MADE BY:

ARCHITECT OF THE CAPITOL
Ford House Office Building
Accounting Office, Room H2-205
Washington, D.C. 20024

CONTRACTING OFFICER WILL COMPLETE ITEM 28 OR 29 AS APPLICABLE

____ 28. NEGOTIATED AGREEMENT (Contractor is required to sign this document and return _____ copies to issuing office.) Contractor agrees to furnish and deliver all items or perform all work, requisitions identified on this form and any continuation sheets for the consideration stated in the contract. The rights and obligations of the parties to this contract shall be governed by (a) this contract award, (b) the solicitation, and (c) the clauses, requirements, certifications, and specifications or incorporated by reference in or attached to this contract.

____ 29. AWARD (Contractor is not required to sign this document.) Your offer on this solicitation, is hereby accepted as to the items listed. This award consummates the contract, which consists of (a) the government solicitation and your offer, and (b) this contract award. No further contractual document is necessary.

30A. NAME AND TITLE OF CONTRACTOR OR PERSON AUTHORIZED TO SIGN
(Type or print)

31A. NAME OF CONTRACTING OFFICER (Type or print)

CHRISTIAN LINDSAY
CONTRACTING OFFICER

30B. SIGNATURE

30C. DATE

31B. UNITED STATES OF AMERICA

31C. AWARD DATE

BY: